

DECLARATION OF PERFORMANCE No: 19CPR-101-EI30-U12

1.	Unique identification of the product-type	SMU101-EI30 U-1,2
2.	Intended use/es	Fire compartmentation routes
3.	Manufacturer	OÜ T-Tammer, Reg nr 10,394201 Peterburi tee 47b, 11415 Tallinn Tel. +372 614 5500 E-mail: info@tammer.ee
4.	Authorised representative	N/A
5.	System of AVCP	System 1 and System 3
6.	Notified product certification Body no.	1) no. 2358 Exova MB Trada (system 1) 2) no. 1336 Inspecta Estonia OÜ (system 3) 3) no. 2018 Kaunas University of Technology Architecture and Construction (system 3)

7.1. Declared performance: (system 1)

Essential Characteristic	Performance	Harmonised Technical specification
Resistance to fire E EI ₁ EI ₂ EW	E15, E20, E30, E45, E60 npd EI ₂ 15, EI ₂ 20, EI ₂ 30 W20, W30, W60	EN 16034:2014
Smoke control	S _a , S ₂₀₀	
Self closing	C-5 (200 000)	
Ability to release*** ***Valid when using the hardware corresponding to EN1125 and EN179	yes	EN 14351-1:2006+A2:2016 p 4.10. Ability to release

7.2. Declared performance: (system 3)

Essential Characteristic	Performance	Harmonised Technical specification
Resistance to wind load	C5	EN 14351-1:2006+A2:2016
Water tightness (outwards opening/inwards opening)	6A/npd	
Acoustic performance R _w (C; C _{tr})	37 dB (-1;-4)	
Thermal transmittance	1,2 W/m ² ·K	
Air permeability	Class 4	
Mechanical strength	Class 3	
Resistance to repeated opening and closing (npd=No performance Determined)	200 000, Class 6	

The performance of the product identified in point 1 and 2 is in conformity with the declared performance in point 7.1. and 7.2.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Signed for and on the manufacturer by:

.....